

- 1. Read the *IAQ*Backgrounder and the Background Information for this checklist.
- 2. Keep the
  Background
  Information and
  make a copy of
  the checklist for
  future reference.
- 3. Complete the Checklist.
  - Check the "yes,"
     "no," or
     "not applicable"
     box beside each
     item. (A "no"
     response requires
     further attention.)
  - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

# **Building and Grounds Maintenance Checklist**

Name: Rob	ert Craig		
School: Canto	n Middle/High Scho	ool	
Room or Area:	Intire Building	Date Completed:	12/22/2025
Signature:	Robert Craig		

1.	BUILDING MAINTENANCE SUPPLIES	Voc	No	N/A
1a.	Developed appropriate procedures and stocked supplies for spill control			
	Reviewed supply labels			
1c.	Ensured that air from chemical and trash storage areas vents to			
	the outdoors	☑		
1d.	Stored chemical products and supplies in sealed, clearly labeled containers	🔽		
1e.	Researched and selected the safest products available			
1f.	Ensured that supplies are being used according to manufacturers'			
	instructions	🔽		
1g.				
1 %	disposed of according to manufacturers' instructions			
1h. 1i.	Substituted less- or non-hazardous materials (where possible)	🗷	_	
11.	when the school is unoccupied	🖸		
1j.	Ventilated affected areas during and after the use of odorous or			
	hazardous chemicals	☑		
2.	GROUNDS MAINTENANCE SUPPLIES			
2a.	Stored grounds maintenance supplies in appropriate area(s)	🛭		
2b.	8			
_	instructions	🖸		
2c.	Established and followed procedures to minimize exposure to fumes			
24	from supplies			
	Replaced portable gas cans with low-emission cans			
2f.	· · · · ·	–	_	_
	containers	🔽		
2g.				
	disposed of according to manufacturers' instructions	🛭		
2	DUST CONTROL			
	Installed and maintained barrier mats for entrances			
	Used high efficiency vacuum bags			
	Used proper dusting techniques			
	Wrapped feather dusters with a dust cloth			

4.	FLOOR CLEANING Yes	. No	o l	N/A	
4a. 4b. 4c.	Established and followed schedule for vacuuming and mopping floors		]		
5.	DRAIN TRAPS				A IS
5b.	Poured water down floor drains once per week (about 1 quart of water) ☑ Ran water in sinks at least once per week (about 2 cups of water) ☑		)		
5c.	Flushed toilets once each week (if not used regularly)		]		
6.	MOISTURE, LEAKS, AND SPILLS				
	Checked for moldy odors		)		
	Inspected ceiling tiles, floors, and walls for leaks or discoloration (may indicate periodic leaks)		נ		
6c.	Checked areas where moisture is commonly generated (e.g., kitchens, locker rooms, and bathrooms)		)		
6d.	Checked that windows, windowsills, and window frames are free of condensate		1		
6e.	Checked that indoor surfaces of exterior walls and cold water pipes are	_			
6f.	free of condensate		J		
	Indoor areas near known roof or wall leaks		)		
	Walls around leaky or broken windows		)		
	Floors and ceilings under plumbing		)		
	Duct interiors near humidifiers, cooling coils, and outdoor air intakes $\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ $		)		
7.	COMBUSTION APPLIANCES				
7a.	Checked for odors from combustion appliances		)		
	Checked appliances for backdrafting (using chemical smoke)   ☑		)		
	Inspected exhaust components for leaks, disconnections, or deterioration   ✓		)		
	Inspected flue components for corrosion and soot $\square$		1		
8.	PEST CONTROL				
8a.	Completed the Integrated Pest Management Checklist		1		

## NOTES



- 1. Read the *IAQ*Backgrounder and the Background Information for this checklist.
- 2. Keep the
  Background
  Information and
  make a copy of
  the checklist for
  future reference.
- 3. Complete the Checklist.
  - Check the "yes,"
     "no," or
     "not applicable"
     box beside each
     item. (A "no"
     response
     requires further
     attention.)
  - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

# **Waste Management Checklist**

Name:	Robert Craig	
School:	Canton Middle/High School	
Room or	Area: Entire Building Date Complete	d: 12/22/2025
Signature	Robert Cagin	

1.	WASTE MANAGEMENT Yes	No	N/A
1a.	Ensured that waste containers are appropriate for use (for example, food waste containers should have lids)		
1b.	Ensured that waste containers are lined		
1c.	Ensured that waste from art, science, vocational classes, etc., are handled separately		
1d.	Labeled recycling bins clearly		
1e.	Ensured number of bins and dumpsters is adequate		
1f.	Ensured appropriate location of dumpsters (i.e., away from air intakes, doors, and operable windows in relation to prevailing winds) ☑		
1g.	Ensured waste containers are emptied regularly		
1h.	Ensured appropriate waste removal schedule		
1i.	Ensured waste is stored in a well-ventilated room		$\square$
1j.	Ensured any exhaust fans in the room are operating properly $\Box$		$\square$
1k.	Checked waste storage areas for odors, contaminants, or signs of vermin $\square$		$\checkmark$

#### **NOTES**

There are no waste storage areas.

Waste is removed directly to outside dumpsters.



- 1. Read the *IAQ*Backgrounder and the Background Information for this checklist.
- 2. Keep the
  Background
  Information and
  make a copy of
  this checklist for
  each ventilation
  unit in your school,
  as well as a
  copy for future
  reference.
- 3. Complete the Checklist.
  - Check the "yes," "no," or "not applicable" box beside each item. (A "no" response requires further attention.)
  - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

## **Ventilation Checklist**


Robert Craig

Name:

Sc	chool: Canton Middle/High School			
111	nit Ventilator/AHU No: Entire Building			
	pom or Area: Entire Building Date Completed: 12/22/2025			
	oom or Area: Date Completed:			
Si	gnature: Robert Craig			
	<u> </u>			
1.	OUTDOOR AIR INTAKES			
1a.	Marked locations of all outdoor air intakes on a small floor plan (for	es	No	N/A
	example, a fire escape floor plan)	<b>2</b>		
1b.	Ensured that the ventilation system was on and operating in "occupied"			
	mode	⊿		
۸.	CTIVITY 1: OBSTRUCTIONS			
	Ensured that outdoor air intakes are clear of obstructions, debris, clogs,			
10.	or covers	<b>2</b>		
1d.	Installed corrective devices as necessary (e.g., if snowdrifts or leaves			
	frequently block an intake)	<b>2</b>		
	NEW TEN A ROLL LUTANT COURCES			
	CTIVITY 2: POLLUTANT SOURCES			
re.	Checked ground-level intakes for pollutant sources (dumpsters, loading docks, and bus-idling areas)	<b>a</b>		
1f.	Checked rooftop intakes for pollutant sources (plumbing vents; kitchen,	_		
	toilet, or laboratory exhaust fans; puddles; and mist from			
	air-conditioning cooling towers)	<b>2</b>		
1g.	Resolved any problems with pollutant sources located near outdoor air	_		
	intakes (e.g., relocated dumpster or extended exhaust pipe)	⊿	u	
AC	CTIVITY 3: AIRFLOW			
	Obtained chemical smoke (or a small piece of tissue paper or light plastic)	<b>2</b>		
	Confirmed that outdoor air is entering the intake appropriately			
2.	SYSTEM CLEANLINESS			
AC	CTIVITY 4: AIR FILTERS			
	Replaced filters per maintenance schedule	<b>2</b>		
2b.	Shut off ventilation system fans while replacing filters (prevents dirt from			
	blowing downstream)			
	Vacuumed filter areas before installing new filters	⊿		
2d.	Confirmed proper fit of filters to prevent air from bypassing (flowing around) the air filter	<b>.</b>		
2e	Confirmed proper installation of filters (correct direction for airflow)			
	2 proper mountained of fineto (contact direction for difficulty)		_	_

#### 2. SYSTEM CLEANLINESS (continued)

#### **ACTIVITY 5: DRAIN PANS** 2f. Ensured that drain pans slant toward the drain (to prevent water from Yes No N/A accumulating) ...... 2g. Cleaned drain pans.... 2h. Checked drain pans for mold and mildew ...... **ACTIVITY 6: COILS** 2i. Ensured that heating and cooling coils are clean ...... **ACTIVITY 7: AIR-HANDLING UNITS, UNIT VENTILATORS** 2j. Ensured that the interior of air-handling unit(s) or unit ventilator (air-mixing chamber and fan blades) is clean ...... **ACTIVITY 8: MECHANICAL ROOMS** 21. Checked mechanical room for unsanitary conditions, leaks, and spills ....... 2m. Ensured that mechanical rooms and air-mixing chambers are free of trash, chemical products, and supplies ...... 3. CONTROLS FOR OUTDOOR AIR SUPPLY 3a. Ensured that air dampers are at least partially open (minimum position) ...... ✓ 3b. Ensured that minimum position provides adequate outdoor air for occupants ...... **ACTIVITY 9: CONTROLS INFORMATION** 3c. Obtained and reviewed all design inside/outside temperature and humidity requirements, controls specifications, as-built mechanical drawings, and controls operations manuals (often uniquely designed) ...... **ACTIVITY 10: CLOCKS, TIMERS, SWITCHES** 3e. Set time clocks appropriately...... ☑ 3f. Ensured that settings fit the actual schedule of building use (including **ACTIVITY 11: CONTROL COMPONENTS** 3g. Ensured appropriate system pressure by testing line pressure at both the occupied (day) setting and the unoccupied (night) setting ...... 3i. Replaced control system filters at the compressor inlet based on the compressor manufacturer's recommendation (for example, when you blow down the tank)..... 3j. Set the line pressure at each thermostat and damper actuator at the proper level (no leakage or obstructions) ...... **ACTIVITY 12: OUTDOOR AIR DAMPERS** 3k. Ensured that the outdoor air damper is visible for inspection...... 31. Ensured that the recirculating relief and/or exhaust dampers are visible for inspection ....... 3m. Ensured that air temperature in the indoor area(s) served by each



*NOTE:* It is necessary to ensure that the damper is operating properly and within the normal range to continue.



3.	CONTROLS FOR OUTDOOR AIR SUPPLY (continued)					
3n.	Checked that the outdoor air damper fully closes within a few minutes	Yes		_		
3o.	of shutting off appropriate air handler	)				
3p.	If in heating mode, checked that the outdoor air damper goes to its minimum position (without completely closing) when the room					
3a.	thermostat is set to 85°F					
•	position (without completely closing) when the room thermostat is set to 60°F and mixed air thermostat is set to 45°F					
3r.	If the outdoor air damper does not move, confirmed the following items:  • The damper actuator links to the damper shaft, and any linkage set					
	screws or bolts are tight	🛭				
	Moving parts are free of impediments (e.g., rust, corrosion)					
	• Electrical wire or pneumatic tubing connects to the damper actuator	🔽				
	• The outside air thermostat(s) is functioning properly (e.g., in the right location, calibrated correctly)					
Pro	ceed to Activities 13–16 if the damper seems to be operating properly.	🕊	_	_		
AC	TIVITY 13: FREEZE STATS					
3s.	Disconnected power to controls (for automatic reset only) to test continuity					
ΩD	across terminals	☑				
OR 3t	Confirmed (if applicable) that depressing the manual reset button (usually					
Э.	red) trips the freeze stat (clicking sound indicates freeze stat was tripped)	🗹				
3u.	Assessed the feasibility of replacing all manual reset freeze-stats with automatic reset freeze-stats	🗹				
clos	TE: HVAC systems with water coils need protection from the cold. The freezeste the outdoor air damper and disconnect the supply air when tripped. The $t_{\rm c}$ ge is 35°F to 42°F.					
AC	TIVITY 14: MIXED AIR THERMOSTATS					
3v.	Ensured that the mixed air stat for heating mode is set no higher than 65°F	🗹				
3w.	Ensured that the mixed air stat for cooling mode is set no lower than the room thermostat setting	🗹				
	TIVITY 15: ECONOMIZERS					
3x.	Confirmed proper economizer settings based on design specifications or local practices	🗹				
NO	TE: The dry-bulb is typically set at 65°F or lower.					
3y.	Checked that sensor on the economizer is shielded from direct sunlight	🗹				
	Ensured that dampers operate properly (for outside air, return air, exhaust/relief air, and recirculated air), per the design specifications					
load Dry	NOTE: Economizers use varying amounts of cool outdoor air to assist with the cooling load of the room or rooms. There are two types of economizers, dry-bulb and enthalpy. Dry-bulb economizers vary the amount of outdoor air based on outdoor temperature, and enthalpy economizers vary the amount of outdoor air based on outdoor temperature.					

and enthalpy economizers vary the amount of outdoor air based on outdoor temperature and humidity level.


#### 3. CONTROLS FOR OUTDOOR AIR SUPPLY (continued)

#### **ACTIVITY 16: FANS** 3aa. Ensured that all fans (supply fans and associated return or relief fans) that move outside air indoors continuously operate during occupied Yes No N/A hours (even when room thermostat is satisfied)...... NOTE: If fan shuts off when the thermostat is satisfied, adjust control cycle as necessary to ensure sufficient outdoor air supply. 4. AIR DISTRIBUTION **ACTIVITY 17: AIR DISTRIBUTION** 4a. Ensured that supply and return air pathways in the existing ventilation system 4b. Ensured that passive gravity relief ventilation systems and transfer grilles between rooms and corridors are functioning ...... NOTE: If ventilation system is closed or blocked to meet current fire codes, consult with a professional engineer for remedies. 4c. Made sure every occupied space has supply of outdoor air (mechanical system or operable windows) ...... NOTE: If outlets have been blocked intentionally to correct drafts or discomfort, investigate and correct the cause of the discomfort and reopen the vents. 4e. Modified the HVAC system to supply outside air to areas without an outdoor air supply ........ $\square$ 4f. Modified existing HVAC systems to incorporate any room or zone layout $\square$ 4g. Moved all barriers (for example, room dividers, large free-standing blackboards or displays, bookshelves) that could block movement of air in the room, especially those blocking air vents ...... 4h. Ensured that unit ventilators are quiet enough to accommodate classroom activities ...... 4i. Ensured that classrooms are free of uncomfortable drafts produced by air from supply terminals ...... **ACTIVITY 18: PRESSURIZATION IN BUILDINGS** NOTE: To prevent infiltration of outdoor pollutants, the ventilation system is designed to maintain positive pressurization in the building. Therefore, ensure that the system, including any exhaust fans, is operating on the "occupied" cycle when doing this activity. 4j. Ensured that air flows out of the building (using chemical smoke) through windows, doors, or other cracks and holes in exterior wall (for example, 5. EXHAUST SYSTEMS **ACTIVITY 19: EXHAUST FAN OPERATION** 5a. Checked (using chemical smoke) that air flows into exhaust fan grille(s) ..... ✓ If fans are running but air is not flowing toward the exhaust intake, check for the following:

• Inoperable dampers

· Broken fan belt

Obstructed, leaky, or disconnected ductworkUndersized or improperly installed fan





#### 5. EXHAUST SYSTEMS (continued)

#### **ACTIVITY 20: EXHAUST AIRFLOW**

and labs by keeping them under negative pressure (as compared to surrounding spaces).						
5b. Checked (using chemical smoke) that air is drawn into the room from adjacent spaces	No	N/A				
Stand outside the room with the door slightly open while checking airflow high and the door opening (see "How to Measure Airflow").	low ii	n				
5c. Ensured that air is flowing toward the exhaust intake ✓						
ACTIVITY 21: EXHAUST DUCTWORK  5d. Checked that the exhaust ductwork downstream of the exhaust fan (which is under positive pressure) is sealed and in good condition						
6. QUANTITY OF OUTDOOR AIR						
ACTIVITY 22: OUTDOOR AIR MEASUREMENTS AND CALCULATIONS						
NOTE: Refer to "How to Measure Airflow" for techniques.						
6a. Measured the quantity of outdoor air supplied (22a) to each ventilation unit	☑					
6b. Calculated the number of occupants served (22b) by the ventilation unit under consideration	☑					
6c. Divided outdoor air supply (22a) by the number of occupants (22b) to determine the existing quantity of outdoor air supply per person (22c) □	⊻					

**ACTIVITY 23: ACCEPTABLE LEVELS OF OUTDOOR AIR QUANTITIES** 6d. Compared the existing outdoor air per person (22c) to the recommended

quantities of outdoor air to ensure that outdoor air quantities (22c) meet the recommended levels in Table 1


6e. Corrected problems with ventilation units that supplied inadequate

levels in Table 1......

NOTE: Prevent migration of indoor contaminants from areas such as bathrooms, kitchens,

#### **NOTES**

We are looking into cunducting measurement calculations.



# Walkthrough Inspection Checklist

Name: Robert Craig	
School: Canton Middle/High School	
Room or Area: Entire Building	Date Completed: 12/22/2025
Signature: Robert Craig	

#### Instructions

- 1. Read the *IAQ*Backgrounder and the Background Information for this checklist.
- 2. Keep the
  Background
  Information and
  make a copy of
  the checklist for
  future reference.
- 3. Complete the Checklist.
  - Check the "yes," "no," or "not applicable" box beside each item. (A "no" response requires further attention.)
  - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

1.	GROUND LEVEL	Yes	No	N/A
	Ensured that ventilation units operate properly			
	Ensured there are no obstructions blocking air intakes			
	Checked for nests and droppings near outdoor air intakes	☑		
	Determined that dumpsters are located away from doors, windows, and outdoor air intakes	<b></b>		
1e.	Checked potential sources of air contaminants near the building (chimneys, stacks, industrial plants, exhaust from nearby buildings)	<b></b>		
1f.	Ensured that vehicles avoid idling near outdoor air intakes			
_	Minimized pesticide application	☑		
1h.	Ensured that there is proper drainage away from the building (including roof downspouts)	<b></b>		
li.	Ensured that sprinklers spray away from the building and outdoor	_		_
	air intakes	☑		
1j.	Ensured that walk-off mats are used at exterior entrances and that they are cleaned regularly	<b></b>		
2.	ROOF			
Wh	ile on the roof, consider inspecting the HVAC units (use the Ventilation Che	ecklis <sup>1</sup>	t).	
2b. 2c. 2d. 2e. 2f.	Ensured that the roof is in good condition  Checked for evidence of water ponding  Checked that ventilation units operate properly (air flows in)  Ensured that exhaust fans operate properly (air flows out)  Ensured that air intakes remain open, even at minimum setting  Checked for nests and droppings near outdoor air intakes  Ensured that air from plumbing stacks and exhaust outlets flows away			
0.	from outdoor air intakes	☑		
3.	ATTIC			
3a.	Checked for evidence of roof and plumbing leaks	<b></b>		
3b.	Checked for birds and animal nests	☑		
4.	GENERAL CONSIDERATIONS			
4a.	Ensured that temperature and humidity are maintained within acceptable ranges	<b>2</b>		
4b.	Ensured that no obstructions exist in supply and exhaust vents			
	Checked for odors			
44	Checked for signs of mold and mildery growth			

<b>4</b> .	GENERAL CONSIDERATIONS (continued)	. No	N/A
4e.			
4f.	Checked for evidence of pests and obvious food sources		
4g.	Noted and reviewed all concerns from school occupants		
5.	BATHROOMS AND GENERAL PLUMBING		
	Ensured that bathrooms and restrooms have operating exhaust fans		
	Water is poured down floor drains once per week (approx. 1 quart of water)		
	Water is poured into sinks at least once per week (about 2 cups of water) ☑		
	Toilets are flushed at least once per week		
6.	MAINTENANCE SUPPLIES		
6a.	Ensured that chemicals are used only with adequate ventilation and when		
	building is unoccupied		
6b.	Ensured that vents in chemical and trash storage areas are operating		
	properly		
	Ensured that portable fuel containers are properly closed $\square$		
6d.	Ensured that power equipment, like snowblowers and lawn mowers, have		
	been serviced and maintained according to manufacturers' guidelines ✓		
7.	COMBUSTION APPLIANCES		
7a.	Checked for combustion gas and fuel odors		
	Ensured that combustion appliances have flues or exhaust hoods		
7c.	Checked for leaks, disconnections, and deterioration		
	Ensured there is no soot on inside or outside of flue components $\square$		
8.	OTHER		
8a.	Checked for peeling and flaking paint (if the building was built before		
	1980, this could be a lead hazard)		
8b.	Determined date of last radon test		

## **NOTES**




- 1. Read the *IAQ*Backgrounder and the Background Information for this checklist.
- 2. Keep the
  Background
  Information and
  make a copy of
  the checklist for
  future reference.
- 3. Complete the Checklist.
  - Check the "yes,"
     "no," or
     "not applicable"
     box beside each
     item. (A "no"
     response
     requires further
     attention.)
  - Make comments in the "Notes" section as necessary.
- Return the checklist portion of this document to the IAQ Coordinator.

# **Integrated Pest Management Checklist**

Name: Robert Craig	
School: Canton Middle/High Scho	ol
Room or Area: Entire Building	Date Completed: 12/22/2025
Signature: Robert Craig	

1.	OFFICIAL POLICY STATEMENT	Yes	No	N/A
1a.	Developed or located the school's official policy statement for integrated pest management (IPM)			
2.	DESIGNATING PEST MANAGEMENT ROLES			
	Assigned and trained a qualified person to be the pest manager			
	Involved decision makers in the IPM program	🗹		
20.	and asked them to keep their areas clean and free of clutter	🗹		
2d.	Encouraged parents to learn about IPM practices and implement them			
20	at home			
	Developed a program to educate and train all IPM participants  Included language about IPM into contracts with pest management	🗷	_	
	professionals	🗹		
3.	SETTING PEST MANAGEMENT OBJECTIVES			
3a.	Set appropriate pest management objectives for school buildings (such as			
	preventing pests from interfering with students' learning environment			
3h	and preserving the integrity of the building structure)	🗷		
50.	providing safe playing areas and the best athletic surfaces possible)	🗹		
4.	INSPECTING, IDENTIFYING, AND MONITORING			
4a.	Inspected all buildings and grounds for pest evidence, entry points,			
	food, water, and harborage sites			
	Identified potential pest habitats in buildings and grounds			
	Pinpointed the source of any current pest problems	☑		
4d.	Monitored to determine the extent of pest problems and to estimate pest populations			
4e.	Developed plans to modify habitat (for example, exclusion, repair, and		_	_
	sanitation efforts) to prevent or resolve any pest problems	🛭		
4f.				
	estimate pest population levels and identify evidence of pests and potential habitat	🔽		

#### 5. SETTING ACTION THRESHOLDS Yes No N/A 5a. Evaluated all available data obtained through inspecting, identifying, and monitoring ...... 5b. Determined how many pests the school buildings, grounds, and 5c. Set action thresholds ...... 6. PREVENTIVE STRATEGIES **INDOOR SITES** 6a. Implemented appropriate strategies to prevent pests from inhabiting the following areas: • Entryways ...... • Classrooms • Gymnasiums ..... • Locker rooms • Offices • Staff lounges ..... • Bathrooms ..... • Food preparation and serving areas ...... • Rooms with extensive plumbing ...... • Maintenance areas ..... • Other ...... **OUTDOOR SITES** 6b. Implemented appropriate strategies to prevent pests from inhabiting the following areas: • Playgrounds ..... • Parking lots. • Lawns and athletic fields..... • Teaching gardens or greenhouses..... • Loading docks ...... $\square$ • Dumpsters ..... • Areas with ornamental shrubs and trees ..... • Other 7. PESTICIDE USE AND STORAGE 7a. Explored alternative pest management methods before concluding that pesticides were necessary...... 7b. Ensured that pest management professionals integrate IPM into their pest management methods ...... 7c. Identified the least toxic, target-specific chemical (or pesticide formulation) that is the most effective to address the pest problem, preferably as baitsand granules ...... 7d. Reviewed and followed all label instructions on pesticides and learned how to properly apply and handle these chemicals ...... 7e. Used spot-treatment (or bait, crack, and crevice applications) to apply pesticides whenever possible and only treated the obviously infested plants in the area ...... 7g. Placed all pesticides in tamper-resistant bait boxes or locations that are






7. PESTICIDE USE AND STORAGE	(cont.)
------------------------------	---------

ħ.	Locked or fastened lids of all bait boxes and placed bait away from the runway of the box	Yes ☑	No □	N/A
i.	Applied pesticides when occupants were not present or in areas where they would not be exposed to the chemicals	🗹		
	Ensured that school occupants (students and staff) are notified of upcoming pesticide applications through posted notices and/or letters	🗹		
	Ensured that parents are notified of upcoming pesticide applications through letters	🖸		
71.	Kept copies of current pesticide labels and information on pesticides easily accessible	🗹		
m.	Stored pesticides off site or in areas that are locked and accessible only to designated personnel	🖸		
'n.	Ensured that storage areas are adequately ventilated and are located away from areas prone to flooding or where spills or leaks may contaminate			
<sup>7</sup> 0.	the environment			<b>V</b>
	Ensured that pesticides are stored in their original containers and all lids are securely fastened			_ <b>✓</b>
q.	Ensured that air in the storage space cannot mix with the air in the central ventilation system			<b>∠</b>
3.	EVALUATING RESULTS AND RECORD KEEPING			
Ba.	Ensured that accurate, up-to-date records of IPM practices and a pest			
11	management log for each property are kept			
	Ensured that pesticide records necessary to meet all state, local, and school board requirements are maintained			
ßc.	Ensured that each log book contains the following items:  • Copy of the pest management plan	🖸		
	• Service schedules for maintenance of buildings and grounds			
	Current EPA-registered labels			
	• Current Material Safety Data Sheets (MSDS) for each pesticide project	🔽		
	Pest surveillance data sheets	🗹		
	• Diagram noting the location of pest activity, traps, and bait stations	🛭		

### **NOTES**

A pest control vendor is used and pesticide is not stored on site.



## **Food Service Checklist**

Name:	Robe	ert Craig		
School:	Cant	on Middle/High School		
Room or	Area:	Entire Building	Date Completed:	12/22/2025
Signature	e:	Robert Craig		

#### Instructions

- 1. Read the *IAQ*Backgrounder and the Background Information for this checklist.
- 2. Keep the
  Background
  Information and
  make a copy of
  the checklist for
  future reference.
- 3. Complete the Checklist.
  - Check the "yes," "no," or "not applicable" box beside each item. (A "no" response requires further attention.)
  - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

#### 1. COOKING AREA

1a.	Determined that local exhaust fans operate properly (note if fans are excessively noisy)		No	N/A
1b.	Checked for odors near cooking, preparation, and eating areas			
	Ensured that exhaust fans are used whenever cooking, washing dishes, and cleaning			
1d.	Determined that gas appliances function properly			
	Verified that gas appliances are vented outdoors			
1f.	Ensured there are no combustion gas or natural gas odors, leaks, backdrafting, or headaches when gas appliances are used	<b>2</b>		
_	Ensured that kitchen is clean after use	<b></b>		
	Checked for signs of microbiological growth in the kitchen, including the upper walls and ceiling (for example, mold, slime, and algae)	<b></b>		
1i.	Selected biocides registered by EPA (if required), followed the manufacturer's directions for use, and carefully reviewed the method of application	☑		
1j.	Verified the kitchen is free of plumbing and ceiling leaks (signs include stains, discoloration, and damp areas)	<b>2</b>		
2.	FOOD HANDLING AND STORAGE			
2a.	Checked food preparation, cooking, and storage areas for signs of insects and vermin (for example, feces or remains)	□ □		
2b.	Stored leftovers in well-sealed containers with no traces of food on outsic surfaces	le		
2c.	Ensured that food preparation, cooking, and storage practices are sanitary		_	
	Disposed of food scraps properly and removed crumbs			_
	Cleaned counters with soap and water or a disinfectant (according to school policy)			_
2f.	Swept and wet mopped floors			
3.	WASTE MANAGEMENT			
	Selected and placed waste in appropriate containers			
	Ensured that containers' lids are securely closed	☑		
	Separated food waste and food-contaminated items from other wastes, if possible			
	Stored waste containers in a well-ventilated area	☑		
3e.	Ensured that dumpsters are properly located (away from air intake vents, operable windows, and food service doors in relation to prevailing winds)	☑		

#### 4. **DELIVERIES**

	Yes	INO	IN/A
4a.	Instructed vendors to avoid idling their engines during deliveries		
4b.	Posted a sign prohibiting vehicles from idling their engines in		
	receiving areas	$\checkmark$	
4c.	Ensured that doors or air barriers are closed between receiving area		
	and kitchen		



## **NOTES**

We will be posting signs regarding engine idling in receiving areas.